

# TAMWORTH MONITORING DATA

<b>Licensee:</b>	Downer Edi Works Pty Ltd	<b>Address:</b>	15-27 Armstrong St Tamworth NSW 2340	<b>EPL No.</b>	<a href="#">12118</a>
<b>Sampling Point:</b>	Outlet Point 2	<b>Month:</b>	October 2015	<b>Published:</b>	December 2015

Stormwater Monitoring Results						
Date Sampled	Report Obtained	Suspended Solids (mg/L)	Suspended Solids Discharge Limit (mg/L)	Oil and Grease (mg/L)	Oil and Grease Discharge Limit (mg/L)	Comments
N/A			50		10	No discharge of stormwater occurred in October 2015.

