

TAMWORTH MONITORING DATA

Licensee: Downer Edi Works Pty Ltd	Address: 15-27 Armstrong St Tamworth NSW 2340	EPL No. 12118
Sampling Point: Outlet Point 2		Published: August 2022

Stormwater Monitoring Results						
Date Sampled	Report Obtained	Suspended Solids (mg/L)	Suspended Solids Discharge Limit (mg/L)	Oil & Grease (mg/L)	Oil & Grease Discharge Limit (mg/L)	Comments
02/08/2022	22/08/2022	18	50	<10	<10	Test complies with discharge limits.

